


कार्यालय – अधीक्षक, सामुदायिक स्वास्थ्य केन्द्र, ज्योतिर्मठ, चमोली

पत्रांक : दिनांक 2025-26/798


दिनांक 30/04/2025


TO WHOMSOEVER IT MAY CONCERN

This is to certify that I have visited Jaypee Vidya Mandir, Vishnupuram, Marwari Colony, Joshimath, District Chamoli (Uttarakhand) and found that Health and Sanitary condition in the School are satisfactory. This is valid upto 31 March 2025.


In-charge / Medical Officer
Community Health Centre, Jyotirmath
District Chamoli (Uttarakhand)

चिकित्सा, अधीक्षक
सामुदायिक स्वास्थ्य केन्द्र
जोशीमठ


Principal
Jaypee Vidya Mandir
Vishnupuram (Marwari)
P. O.- Joshimath, District- Chamoli
Pin-246443 (Uttarakhand)


Manager
Jaypee Vidya Mandir
Vishnupuram (Marwari)
P. O. Joshimath, District Chamoli
Pin- 246443 (Uttarakhand)



EKO TESTING LABS®

Eko Pro Engineers Pvt. Ltd.

Competence | Quality | Service



ULR -TC420124100000355F

TEST REPORT

Water Sample Analysis

Test Report No. : EKO/E-019/280924

Issue Date : 03/10/2024

Issued To

: JAYPEE VIDYA MANDIR,
(Vishnuprayag Hydro Electric Project)
Joshimath
Chamoli - Uttarakhand

Sample Description : Drinking Water
Sample Drawn on : 26/09/2024
Sample Drawn by : EPEPL (Mr. Amit Kumar)
Sample Received on : 28/09/2024
Sampling Location : From Jaypee Vidya Mandir
Sampling Plan & Procedure : SOP-W/66
Sample Quantity : 1.0 Litre
Environmental Conditions : Normal
Analysis Duration : 28/09/2024 To 03/10/2024
Remark (if any) : NA

RESULTS

S. No.	Parameters	Test Methods	Results	Units	Limits as per IS:10500-2012	
					Acceptable	Permissible
1	Colour	IS: 3025 (P-4)-A : 2021	BLQ (LOQ-1.0)	Hazen	5	15
2	Odour	IS: 3025 (P-5) : 2018	Agreeable	—	Agreeable	Agreeable
3	Taste	IS: 3025 (P-7) : 2017	Agreeable	—	Agreeable	Agreeable
4	Turbidity	IS: 3025 (P-10) : 2023	BLQ (LOQ-1.0)	NTU	1	5
5	pH	IS: 3025 (P-11) 2.0 : 2022	6.92	—	6.5-8.5	No relaxation
6	Total Hardness (as CaCO ₃)	IS: 3025 (P-21)-A : 2009	35.0	mg/L	200	600
7	Total Alkalinity (as CaCO ₃)	IS: 3025 (P-23) : 1986	29.0	mg/L	200	600
8	Chloride (as Cl)	IS: 3025 (P-32)-2.0 : 1988	20.5	mg/L	250	1000
9	Residual Free Chlorine	IS: 3025 (P-26)-C : 2021	BLQ (LOQ-0.1)	mg/L	0.2	1
10	Fluoride (as F)	IS: 3025 (Part - 60) -B : 2008	BLQ (LOQ-0.1)	mg/L	1	1.5
11	Total Dissolved Solids	IS: 3025 (P-16) : 2023	136.0	mg/L	500	2000
12	Total Coliform	IS: 15185 : 2016	Not Detected	Per 100mL	Should be Not Detectable	

Notes:

- The results given above are related to the tested sample, as received & mentioned parameters. The customer asked for the above tests only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the Laboratory.
- The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer. Sample received for biological tests will be destroyed after 7 days from the date of issue of test report.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- BLQ=Below Limits of Quantification, LOQ= Limits of Quantification

End of Report

